




3,000 – 5,200 GALLON




Leg X-Sect.



A — 6 Req'd.



B = 2 Req'd.



C - 1 Req'd.



ELEVATION

Weld gussets together, then weld to base.
All welds 1/4 fillet, continuous.

Dwg. 3k-5200g EQR

Qty. 4
Finish Galvanized

IMPORTANT: MINIMUM OF 4" FROM EDGE OF CONCRETE TO CENTERLINE OF BOLT HOLES (3) REQUIRED. TANK PAD WIDTH AND/OR LENGTH MAY NEED TO BE ADJUSTED.