

539AS Diffuser for 2" Drop Tube

Installation & Maintenance Instructions



Failure to follow any or all of the warnings may render the part nonfunctional and could result in a hazardous product spill, which may result in property damage, environmental contamination, fire, explosion, injury or death.

Installation



WARNINGS

- **Fire Hazard**—Death or serious injury could result from spilled liquids.
- Any modification to this product other than stated in these installation instructions will void the product warranty.
- Install in accordance with all applicable local, state, and federal laws.
- For your safety, it is important to follow local, state, federal and/or OSHA rules that apply to working inside, above, or around the storage tank and piping area. Use all personal protective equipment required for working in the specific environment.
- Tanks could be under pressure. Vapors could be expelled from tank vents, piping, valves or fittings while performing installation. Vapors could catch fire or cause an explosion. Avoid sparks, open flame, or hot tools when working on tanks.
- Fill points should be labeled to identify product being transferred, according to all applicable codes.
- In the event of malfunction, contact Morrison Bros. Co. customer service.

Steps

1. Check drop tube. This method is for a drop tube with an outside diameter of no more than 2".
2. Measure the distance from the top of the riser pipe to the bottom of the tank.
3. Using the Drop Tube Length Calculator, calculate the length of the drop tube and cut the end of the drop tube square. (Cut end of drop tube should be 6 inches from bottom of tank.)
4. Place the attached Hole Location Template onto the tube so the bottom edge of the sheet is flush with the bottom edge of the tube.
5. Using the template, lightly punch hole locations and drill through the tube with a #2 drill (0.221").
6. Remove the template from the drop tube.
7. Place nut clips on tube and align with holes in tube.
8. Place diffuser on tube, align holes, and loctite enclosed screws.

Drop Tube Length Calculator

_____ = Measured distance from
top of riser pipe to
bottom of tank.

- 6 inches =

_____ = = Required length of
drop tube.

Maintenance

This product should be maintained according to local codes.



WARNINGS

- **Fire Hazard** – Death or serious injury could result from spilled liquids.
- You must be trained to maintain this product. Stop now if you have not been trained.
- For your safety, it is important to follow local, state, federal and/or OSHA rules that apply to working inside, above, or around the storage tank and piping area. Use all personal protective equipment required for working in the specific environment.
- Tanks could be under pressure. Vapors could be expelled from tank vents, piping, valves or fittings while performing maintenance. Vapors could catch fire or cause an explosion. Avoid sparks, open flame, or hot tools when working on tanks and tank accessories.

WARRANTY: If you believe this product has a defect due to material or workmanship, please contact Morrison for a return authorization. All products are thoroughly tested before shipment and meet all applicable performance standards and specifications. Only material found to be defective in manufacture will be replaced or repaired at our discretion. Claims must be made within one year from the date of installation, and Morrison Bros. Co. will not allow claims for labor or consequential damage resulting from purchase, installation or misapplication of the product. The warranty registration information must be provided to the end user.


Hole Location Template

539AS-0207 PP, Rev A




Hole Location Template

539AS-0207 PP, Rev A



Hole Location Template

539AS-0207 PP, Rev A



Hole Location Template

539AS-0207 PP, Rev A

