







TANK SUMP BOX: ---THICKNESS: INNER - 7 GAUGE THICKNESS: OUTER - 7 GAUGE CONSTRUCTION: LAP WELD OUTSIDE TANK TEST: INNER - 5 PSIG TANK TEST: OUTER - 3 PSIG **EXTERIOR FINISH:** CONCRETE ENCASED OPTION TYPE: EXPOSED AGGREGATE OPTION TYPE: MASTERPROTECT HB400 (PAINTED) LABEL: UL2085 & UL752 TANK WEIGHT: APPROX. 31,700LBS. engineered solutions safety, compliance, reliability, **LOCATION & CONTACT** WASHINGTON DC (HEADQUARTERS) 620 HERNDON PARKWAY, SUITE 120 HERNDON, VA 20170 PHONE: (800)628-5502 **NEW YORK** 8 AIRLINE DRIVE, SUITE 110 ALBANY, NY 12205 PHONE: (518)635-4343 PROJECT NAME AND ADDRESS: STANDARD MFG. DRAWING THIS DOCUMENT IS THE PROPERTY OF CORE ENGINEERED SOLUTIONS. DO NOT REPRODUCE, FURNISH TO OTHERS, OR USE FOR OTHER THAN PURPOSE INTENDED WITHOUT EXPRESS WRITTEN CONSENT OF CORE

DATE: 04/17/2024

SCALE: REFER TO NOTES

DRAWING: CVTDW-02000-FRM

REV: 000

SHEET NO.

CVT

2K

DESIGN DATA:

MODEL NO: CVTDW-02000-FRM

TYPE: DOUBLE WALL - TYPE I

OPERATING PRESSURE: ATMOSPHERIC

TANK MATERIAL: MILD CARBON STEEL A36

TANK OVERFILL CONTAINER: 7 GALLON W/ 4"

FILL, 2" STICK PORT & DRAIN VALVE

PRODUCT STORED: -

SPECIFIC GRAVITY: 1.0

TANK FITTINGS: NPT

TANK MANWAY: ---

NO. REQ.: 1